

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 214 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemvwd@verizon.net

March 14th Wednesday 7pm

- There are 311 meters in service.
- We did our Iron and Manganese 1st quarter sample.
- Regular upkeep and maintenance was performed.
- Still working with Badger meter on our new read software. I hope it will be up and running soon so we can then start working on replacing meter heads to get a better read percent. Training is set for 3/13 + 3/14.

Training went good cant wait to give it a full run.

- I fixed one water meter that was leaking due to normal usage.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- All fire hydrants are in service.
- Working on a spring time to do list and also some up coming projects and some new equipment that we will be needing.
- The Town updated there web page (water) for me. I think it looks good and there is some good information there if anyone wants to see whats going on there and also what the water quality is.
- Our up coming water tests this year are
 - Coliform - Monthly
 - Iron + Manganese - Quarterly (March,June,September,December)
 - Nitrate - Lead & Copper - Secondary Inorganic Chemicals - Principle Organic Chemicals. We will be doing these tests around July.
- We had one application put in for a new water hook up.

Thank You,

Eric Rogers

Class C Water Plant Operator

*** Saratoga Water School in Wednesday April 11th