

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

May 9th Wednesday 7pm

- There are 311 meters in service.
- We went to a water school in Saratoga.
- There is a water class in Lake George for \$20. I think it looks like a good class. This class is in July. Its on Safety for water operators. It will cover Excavations, Confined Space, Traffic Control and PPE.
- Regular upkeep and maintenance was performed.
- We are going to try flushing dead end fire hydrants every other week. We have 17 of them and we hope if we start early in the morning and flush 1/2 of them one week and a couple weeks later flush the other 1/2 it will help keep water moving from the dead ends.
- Fire hydrant flushing went very good.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- All fire hydrants are in service.
- We did in house safety training on SDS, PPE, and Lock Out - Tag Out.
- Our up coming water tests this year are
 - Coliform - Monthly
 - Iron + Manganese - Quarterly (March,June,September,December)
 - Nitrate - Lead & Copper - Secondary Inorganic Chemicals - Principle Organic Chemicals. We will be doing these tests around July.
-
-
-

Thank You,

Eric Rogers

Class C Water Plant Operator