

**SALEM WATER DEPARTMENT  
53 STANTON HILL ROAD, SALEM, NY 12865 phone  
and fax 854-9712**

**MONTHLY REPORT  
November 9th 2016**

- There are 310 meters in service.
- There was a new water hook up this month.
- We turned off our seasonal water hookups.
- Regular upkeep and maintenance was performed.
- I worked on cleaning out some more main valves.
- We flushed all the fire hydrants. The flushing went good. We will need to be painting them next year.
- I pumped out all 70 hydrants and they are set for winter. If the fire department needs water they can still be used I just need to be notified so I can re-pump it out so it does not freeze.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- I did go through and updated and added new Safety Data Sheets so we can stay up on the log book.
- Kubota is all ready for winter

**Thank You,  
Eric Rogers  
Class C Water Plant Operator**