

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

November 14th Wednesday 7pm

- There are 314 meters in service.
- We had no new hook ups for the month of November.
- Regular upkeep and maintenance was performed.
- We went to use well #3 and it would not run. We contacted Mark Rogers and the Department of Health to let them no of our problem. Well #3 is our back up well and we can still run regular with out it but we have to fix it. Mark has looked at it and will be hear to fix it once he gets a couple things lined up.
- Fire Hydrant flushing went good. We did our main flush on Saturday Oct 27th and Sunday Oct 28th. We also did a flushing of all the dead end Hydrants on Thursday Nov 1st. There seems to be no major issues with any hydrants.
- All Hydrants have been pumped out and are ready for winter. I ask if any hydrant is used to contact the water department so it can be re-pumped.
- I have been working on up dating some curb stop maps.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- Fire extinguisher got there yearly inspection.
- All fire hydrants are in service.
- We have changed our pump setting for Chlorine and K5. It seems to be working good. We hope to use less K5 with less waste.
- Once the cold weather gets hear I am planing on working more on getting my NO READ fixed so come spring we can get a better read %.
- Our up coming water tests this year are
 - Coliform - Monthly
 - Iron + Manganese - Quarterly (December)

Thank You,

Eric Rogers

Class C Water Plant Operator