

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

November 10th - 2021

- There are 316 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number.
- Regular upkeep and maintenance was performed.
- We flushed all the fire hydrants. Flushing went good with no issues.
- The old shirt shop did a water hook up for a 6" water main for fire protection and also a 2" line for there day to day usage. We had to do a boil water notice for the area where the work was done.
- We did a hand full for Dig Safe mark outs.
- We did a hand full of water tests this month - waiting in results to come back. All are good. We did one test before and one test after we flushed hydrants. We had to do 2 tests when we cleaned well #1, and we had to do 2 more tests for the 5 Park Place water hook up.
- Grass has been growing fast and have been mowing it down at water barn.
- All fire hydrants have been winterized and ready for winter.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- We need to have the office door at the water barn replaced
- We did the well cleaning for well #1. It went good and we got a little better flow from it. Hope we can clean well #2 next year.

*****If a hydrant has to be used PLEASE notify the water department as soon as possible so we can pump it out when done so it will not freeze*****

Thank You,

Eric Rogers

Class C Water Plant Operator