

**SALEM WATER DEPARTMENT  
53 STANTON HILL ROAD, SALEM, NY 12865  
phone and fax 854-9712**

**MONTHLY REPORT  
October 12<sup>th</sup> 2016**

- **There are 309 meters in service.**
- **Regular upkeep and maintenance was performed.**
- **I worked on cleaning out some more main valves.**
- **We have been flushing dead end fire hydrants to keep water moving so it will stay clean and drinkable. We are done flushing dead ends till next year. Hydrant Flushing went good – all done.**
- **We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.**
- **We did our 3<sup>rd</sup> Quarter Mn and Ir test.**
- **I did go through and updated and added new Safety Data Sheets so we can stay up on the log book.**
- **Hydrant #41 is back online.**
- **Water Tank – We had the water tank inspected and cleaned. This was done on the 12<sup>th</sup> of September. The video and reports clam that our water tank is in good condition and was cleaned so there is nothing on the bottom of the tank. DOH seems good with what we did. I have the report and a video in the office of the cleaning and inspection.**
- **Well #3 has been pulled / took a video of the dirty well. Then the well was cleaned with a brush and air pressure. Then was left alone overnight. The next day we re-videoed it. Well looks good and then we washed off the pipes – wires and pump and then reinstalled it. I pumped a bunch of water out our blow off and then took a sample to Queensbury it passed. Back available if needed.**

**Thank You,  
Eric Rogers  
Class C Water Plant Operator**