

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 214 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemvwd@verizon.net

October 11th 7pm 2017

- There are 310 meters in service.
- There was no new water hook ups this month.
- Regular upkeep and maintenance was performed.
- Eye wash and Fire Hydrant checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- We did our fall fire hydrant flushing
- We will be stopping our dead end flushing
- Still working with Badger meter on our new read software. I hope it will be up and running soon so we can then start working on replacing meter heads to get a better read percent.

Thank You,

Eric Rogers

Class C Water Plant Operator

- We will be getting the Fire Hydrants all ready for winter. We will clean the caps - put a food grade lube on them and also pump the water out so they will not freeze. Final maintenance will be done before winter. Also at this time - I would like to ask the Fire Department to notify Eric or Travis if a hydrant is used so we can make sure it gets re-winterized.