

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

October 14th Wednesday 7pm

- There are 315 meters in service.
- Regular upkeep and maintenance was performed.
- We have been flushing dead end fire hydrants to keep water moving.
- We did a hand full for Dig Safe mark outs.
- All Fire Hydrants are in service.
- Did a water FREE online training class (Flushing and flow testing).
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- Started to “winterize” some fire hydrants. Checking oil leaves - changing markers when needed and cleaning the caps and threads so they open easy. I’m hoping by doing this that my winter pump out and checks will go a little faster.
- I have been working on up dating some curb stop maps - also started to add some highway drain stuff to the diamond mapping program.
- We need to have the office door at the water barn replaced.
- Septic at water barn was pumped out.
- Started to winterize and check over Hydrants before winter gets hear.

***We will start our fall hydrant flushing the week of Columbus day 10/12-16/2020. Please post this in the town paper. I would like to be able to start flushing sometime between 4-6am**

Thank You,

Eric Rogers

Class C Water Plant Operator