

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 214 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemvwd@verizon.net

September 13th 7pm 2017

- There are 310 meters in service.
- There was no new water hook ups this month.
- On fire hydrant #3 we put a 12” riser so the hydrant will be up to grade leave. “Quarry Road”.
- Regular upkeep and maintenance was performed.
- Eye wash and Fire Hydrant checks have been done.
- We fixed 3 curb stop boxes this month.
- We fixed 3 main valve boxes this month.
- Eye wash and Fire Hydrant checks have been done.
- We did our monthly water sample required by the D.O.H. it MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- We have got the new meter heads we ordered. We are waiting on the read software. Once we get the new system up and running we will start changing out old meter heads with new ones to be able to get a better accounting on used water.
- We have been doing dead end fire hydrant flushing. This has been going good and will be on going threw out the summer into fall until we do our fall flushing.

Thank You,

Eric Rogers

Class C Water Plant Operator