

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

September 11th Wednesday 7pm

- There are 315 meters in service.
- Regular upkeep and maintenance was performed.
- We have been flushing dead end fire hydrants to keep water moving.
- We did a hand full for Dig Safe mark outs.
- All Fire Hydrants are in service.
- We did out 3rd quarter iron and manganese testing.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- Travis and I are signed up for a water class in October.
- I have been working on up dating some curb stop maps.
- We need to have the office door at the water barn replaced.
- We fixed the tank / computer communication issue. We have not had loss the signal issues sense we put on the new antenna at the barn.
- Working on up dating DEC water withdrawal permit. All we need to do with this is change the ownership from the Village to the Town. I hope I have it all set.

*We will start our fall hydrant flushing the week of
Columbus day 10/14-18/2019. Please post this in the
town paper.

Thank You,

Eric Rogers

Class C Water Plant Operator

