

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

September 8th Wednesday 7pm

- There are 316 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number.
- Regular upkeep and maintenance was performed.
- Finally finished painting fire hydrants. Got 25 done / 50 left to do in the up coming year or two.
- Should be having a new hook up soon. The old CB Sports building is looking for a new 2" line. Also to install a 6" main for fire protection. Up dates will be at there cost.
- We did a hand full for Dig Safe mark outs.
- We did a hand full of water tests this month - waiting in results to come back.
- Grass has been growing fast and have been mowing it down at water barn.
- We got our computer fixed at the water barn. Hope we get some bids and can do the much needed updates to our computer run system.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- We need to have the office door at the water barn replaced
- Talked with Mark Rogers and hope to be doing a well clean soon.

***** We will start our fall hydrant flushing the week of Columbus day 10/11-15/2021. Please post this in the town paper *****

I will be a way the week of the 13th

Thank You,

Eric Rogers

Class C Water Plant Operator