


Water Systems Operation Report
Microbiological Sample Results

Public Water System Name	Reporting Month/Year	Date Report Submitted	Source of Water Supply:
Town of Salem Water Department	January 2023	2/2/2023	<input type="checkbox"/> Surface <input checked="" type="checkbox"/> Ground <input type="checkbox"/> GWUDI
Public Water System ID	County	Town, Village, or City	<input type="checkbox"/> Purchase with subsequent chlorination
5730106	Washington	Town of Salem	<input type="checkbox"/> Purchase w/out subsequent chlorination

DATE	Treated water volume (1,000 gallons/day)	Chlorination				Other Treatments / Readings	
		Gaseous		Liquid	Free chlorine residual at entry point (mg/l)	orthophosphate residual	
		Cylinder weight (lbs.)	Chlorine used per day (lbs.)	Hypochlorite added to crock (gallons or quarts)			
1	34432				1.79	1.19	
2	32199				1.81	1.07	
3	47653				1.89	1.68	
4	31976				1.77	1.52	
5	47616				1.86	2.1	
6	44016				1.86	1.8	
7	39234				1.82	1.79	
8	31596				1.82	1.63	
9	41026				1.79	1.54	
10	34836				1.78	1.68	
11	41856				1.71	1.6	
12	32120				1.74	1.57	
13	45860				1.68	1.59	
14	33404				1.73	1.5	
15	44020				1.58	1.31	
16	33904				1.62	1.37	
17	47668				1.41	1.17	
18	32488				1.69	1.28	
19	48812				1.7	1.24	
20	32796				1.71	1.2	
21	44960				1.62	1.28	
22	32444				1.61	1.42	
23	43832				1.67	1.38	
24	35012				1.59	1.31	
25	40976				1.79	1.48	
26	28144				1.74	1.94	
27	43868				1.68	1.82	
28	33348				1.78	1.84	
29	45560				1.67	1.73	
30	33092				1.75	1.28	
31	48456				1.81	1.39	
Total	1207204					46.7	
AVG.	38942.065				1.72484	1.5065	

Does a M&AR violation exist? No Does an MCL violation exist? No Population Served 915
 Did an emergency occur in any part of the water system? No Does the system have a disinfection waiver? No

Reported by: Eric Rogers Title: Water Plant Operator Certification Number: NY0036794
 Signature:  Date: 2/2/2023 Operator Grade Level C