



**SAMPLE INFORMATION**

|                                  |  |                      |                    |
|----------------------------------|--|----------------------|--------------------|
| <b>Sample ID</b>                 | JH2204483  | <b>Customer Code</b> | 1952               |
| <b>Federal Water Supply Code</b> | NY5730106  |                      |                    |
| <b>Water Supply</b>              | Town of Salem Water Department                       |                      |                    |
| <b>Address</b>                   | PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865 |                      |                    |
| <b>Sample Location</b>           | Well 1 Raw   |                      |                    |
| <b>Date Collected</b>            | 6/9/2022   | <b>Free Chlorine</b> | <b>Temperature</b> |
| <b>Sample Collector</b>          | Eric Rogers  |                      |                    |
| <b>Date Printed</b>              | 6/30/2022  |                      |                    |

**LABORATORY REPORT**

| ANALYTE                | CONCENTRATION MG/L | MCL          | METHOD    | Date analyzed | NYS Lab |
|------------------------|--------------------|--------------|-----------|---------------|---------|
| Dissolved Iron         |                    | <0.05 - 0.30 | EPA 200.7 |               |         |
| Dissolved Manganese    |                    | <0.01 - 0.30 | EPA 200.7 |               |         |
| Iron                   | 0.125              | <0.05 - 0.30 | EPA 200.7 | 6/16/2022     | 11549   |
| Manganese              | 0.0964             | <0.01 - 0.30 | EPA 200.7 | 6/16/2022     | 11549   |
| Thallium               |                    | 0.002        | EPA 200.8 |               |         |
| Sodium                 |                    | ***          | EPA 200.7 |               |         |
| Aluminum               |                    |              | EPA 200.7 |               |         |
| Calcium                |                    |              | EPA 200.7 |               |         |
| Aluminum, Dissolved    |                    |              | EPA 200.7 |               |         |
| Total Dissolved Solids |                    |              | SM2540C   |               |         |
| Ammonia                |                    |              | EPA 350.1 |               |         |
| Nickel                 |                    |              |           |               |         |

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:



**SAMPLE INFORMATION**

|                                  |  |                      |                    |
|----------------------------------|--|----------------------|--------------------|
| <b>Sample ID</b>                 | JH2204484  | <b>Customer Code</b> | 1952               |
| <b>Federal Water Supply Code</b> | NY5730106  |                      |                    |
| <b>Water Supply</b>              | Town of Salem Water Department                       |                      |                    |
| <b>Address</b>                   | PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865 |                      |                    |
| <b>Sample Location</b>           | Well 2 Raw   |                      |                    |
| <b>Date Collected</b>            | 6/9/2022   | <b>Free Chlorine</b> | <b>Temperature</b> |
| <b>Sample Collector</b>          | Eric Rogers  |                      |                    |
| <b>Date Printed</b>              | 6/30/2022  |                      |                    |

**LABORATORY REPORT**

| ANALYTE                | CONCENTRATION MG/L | MCL          | METHOD    | Date analyzed | NYS Lab |
|------------------------|--------------------|--------------|-----------|---------------|---------|
| Dissolved Iron         |                    | <0.05 - 0.30 | EPA 200.7 |               |         |
| Dissolved Manganese    |                    | <0.01 - 0.30 | EPA 200.7 |               |         |
| Iron                   | <0.0500            | <0.05 - 0.30 | EPA 200.7 | 6/16/2022     | 11549   |
| Manganese              | 0.222              | <0.01 - 0.30 | EPA 200.7 | 6/16/2022     | 11549   |
| Thallium               |                    | 0.002        | EPA 200.8 |               |         |
| Sodium                 |                    | ***          | EPA 200.7 |               |         |
| Aluminum               |                    |              | EPA 200.7 |               |         |
| Calcium                |                    |              | EPA 200.7 |               |         |
| Aluminum, Dissolved    |                    |              | EPA 200.7 |               |         |
| Total Dissolved Solids |                    |              | SM2540C   |               |         |
| Ammonia                |                    |              | EPA 350.1 |               |         |
| Nickel                 |                    |              |           |               |         |

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:



**SAMPLE INFORMATION**

|                                  |  |                      |                    |
|----------------------------------|--|----------------------|--------------------|
| <b>Sample ID</b>                 | JH2204485  | <b>Customer Code</b> | 1952               |
| <b>Federal Water Supply Code</b> | NY5730106  |                      |                    |
| <b>Water Supply</b>              | Town of Salem Water Department                       |                      |                    |
| <b>Address</b>                   | PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865 |                      |                    |
| <b>Sample Location</b>           | Well 3 Raw   |                      |                    |
| <b>Date Collected</b>            | 6/9/2022   | <b>Free Chlorine</b> | <b>Temperature</b> |
| <b>Sample Collector</b>          | Eric Rogers  |                      |                    |
| <b>Date Printed</b>              | 6/30/2022  |                      |                    |

**LABORATORY REPORT**

| ANALYTE                | CONCENTRATION MG/L | MCL          | METHOD    | Date analyzed | NYS Lab |
|------------------------|--------------------|--------------|-----------|---------------|---------|
| Dissolved Iron         |                    | <0.05 - 0.30 | EPA 200.7 |               |         |
| Dissolved Manganese    |                    | <0.01 - 0.30 | EPA 200.7 |               |         |
| Iron                   | 0.114              | <0.05 - 0.30 | EPA 200.7 | 6/16/2022     | 11549   |
| Manganese              | 0.413              | <0.01 - 0.30 | EPA 200.7 | 6/16/2022     | 11549   |
| Thallium               |                    | 0.002        | EPA 200.8 |               |         |
| Sodium                 |                    | ***          | EPA 200.7 |               |         |
| Aluminum               |                    |              | EPA 200.7 |               |         |
| Calcium                |                    |              | EPA 200.7 |               |         |
| Aluminum, Dissolved    |                    |              | EPA 200.7 |               |         |
| Total Dissolved Solids |                    |              | SM2540C   |               |         |
| Ammonia                |                    |              | EPA 350.1 |               |         |
| Nickel                 |                    |              |           |               |         |

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

**SAMPLE INFORMATION**

|                                  |  |                      |                    |
|----------------------------------|--|----------------------|--------------------|
| <b>Sample ID</b>                 | JH2204486  | <b>Customer Code</b> | 1952               |
| <b>Federal Water Supply Code</b> | NY5730106  |                      |                    |
| <b>Water Supply</b>              | Town of Salem Water Department                       |                      |                    |
| <b>Address</b>                   | PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865 |                      |                    |
| <b>Sample Location</b>           | Finished   |                      |                    |
| <b>Date Collected</b>            | 6/9/2022   | <b>Free Chlorine</b> | <b>Temperature</b> |
| <b>Sample Collector</b>          | Eric Rogers  |                      |                    |
| <b>Date Printed</b>              | 6/30/2022  |                      |                    |

**LABORATORY REPORT**

| ANALYTE                | CONCENTRATION MG/L | MCL          | METHOD    | Date analyzed | NYS Lab |
|------------------------|--------------------|--------------|-----------|---------------|---------|
| Dissolved Iron         |                    | <0.05 - 0.30 | EPA 200.7 |               |         |
| Dissolved Manganese    |                    | <0.01 - 0.30 | EPA 200.7 |               |         |
| Iron                   | <0.0500            | <0.05 - 0.30 | EPA 200.7 | 6/16/2022     | 11549   |
| Manganese              | 0.0811             | <0.01 - 0.30 | EPA 200.7 | 6/16/2022     | 11549   |
| Thallium               |                    | 0.002        | EPA 200.8 |               |         |
| Sodium                 |                    | ***          | EPA 200.7 |               |         |
| Aluminum               |                    |              | EPA 200.7 |               |         |
| Calcium                |                    |              | EPA 200.7 |               |         |
| Aluminum, Dissolved    |                    |              | EPA 200.7 |               |         |
| Total Dissolved Solids |                    |              | SM2540C   |               |         |
| Ammonia                |                    |              | EPA 350.1 |               |         |
| Nickel                 |                    |              |           |               |         |

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodiium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample