



**SAMPLE INFORMATION**

<b>Sample ID</b>	JH2210905	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
<b>Sample Location</b>	Raw Well 1		
<b>Date Collected</b>	12/20/2022	<b>Free Chlorine</b>	<b>Temperature</b>
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	1/23/2023		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.0501	<0.05 - 0.30	EPA 200.7	1/11/2023	11549
Manganese	0.100	<0.01 - 0.30	EPA 200.7	1/16/2023	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:



**SAMPLE INFORMATION**

<b>Sample ID</b>	JH2210906	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
<b>Sample Location</b>	Raw Well 2		
<b>Date Collected</b>	12/20/2022	<b>Free Chlorine</b>	<b>Temperature</b>
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	1/23/2023		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.168	<0.05 - 0.30	EPA 200.7	1/11/2023	11549
Manganese	0.111	<0.01 - 0.30	EPA 200.7	1/16/2023	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



**SAMPLE INFORMATION**

<b>Sample ID</b>	JH2210907	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
<b>Sample Location</b>	Raw Well 3		
<b>Date Collected</b>	12/20/2022	<b>Free Chlorine</b>	<b>Temperature</b>
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	1/23/2023		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	<0.0500	<0.05 - 0.30	EPA 200.7	1/11/2023	11549
Manganese	0.272	<0.01 - 0.30	EPA 200.7	1/16/2023	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



**SAMPLE INFORMATION**

<b>Sample ID</b>	JH2210908	<b>Customer Code</b>	1952
<b>Federal Water Supply Code</b>	NY5730106		
<b>Water Supply</b>	Town of Salem Water Department		
<b>Address</b>	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
<b>Sample Location</b>	Finished Water		
<b>Date Collected</b>	12/20/2022	<b>Free Chlorine</b>	<b>Temperature</b>
<b>Sample Collector</b>	Eric Rogers		
<b>Date Printed</b>	1/23/2023		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION	MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron			<0.05 - 0.30	EPA 200.7		
Dissolved Manganese			<0.01 - 0.30	EPA 200.7		
Iron	0.266		<0.05 - 0.30	EPA 200.7	1/11/2023	11549
Manganese	0.380		<0.01 - 0.30	EPA 200.7	1/16/2023	11549
Thallium			0.002	EPA 200.8		
Sodium			***	EPA 200.7		
Aluminum				EPA 200.7		
Calcium				EPA 200.7		
Aluminum, Dissolved				EPA 200.7		
Total Dissolved Solids				SM2540C		
Ammonia				EPA 350.1		
Nickel						

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample