

Queensbury Laboratory  
Accredited in accordance with NELAC

Queensbury Water Department  
823 Corinth Rd  
Queensbury, N.Y. 12804-9725  
(518) 793-8866  
New York State Certification # 10565  
EPA Lab Code # NY01262

Report of Bacteriological Examination

---

Date Collected: 4/6/2022

Date Tested: 4/6/2022

Collected By: Eric Rogers

Sample Point: Kitchen Faucet

Address of Sample: 11 McDougal St Salem, NY 12865-

Supplier: Salem Water Department

Fed Id: 5730106

Sample Number: 98187

Time Collected: 7:45 AM

Time Tested: 2:37 PM

Sample Age (hours)  
6.87

Total Coliform: Total Coliform Bacteria Absent per 100ml Sample

Heterotrophic Plate Count (#/1ml):

E. Coli:

Field tested Free Chlorine: 1.45

---

Procedures Used:

Coliform, Total / E. coli (Qualitative) SM 21, 23 9222A,B,C

E. coli (Enumeration) SM 21, 23 9222A,B,C

Heterotrophic Plate Count SM 20, 21-23 9215B (-04)

**At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.**

Sample Qualifier:



Laboratory Director or Designee