

Queensbury Laboratory  
Accredited in accordance with NELAC

Queensbury Water Department  
823 Corinth Rd  
Queensbury, N.Y. 12804-9725  
(518) 793-8866  
New York State Certification # 10565  
EPA Lab Code # NY01262

Report of Bacteriological Examination

---

Date Collected: 1/10/2023

Sample Number: 333

Date Tested: 1/10/2023

Time Collected: 11:00 AM

Collected By: Eric Rogers

Time Tested: 1:25 PM

Sample Point: Kitchen Faucet

Address of Sample: Proudfit Hall- 181 Main St Salem, NY 12865-

Supplier: Salem Water Department

Sample Age (hours)

Fed Id:5730106

2.42

Total Coliform: Total Coliform Bacteria Absent per 100ml Sample

Heterotrophic Plate Count (#/1ml):

E. Coli:

Field tested Free Chlorine: 1.71

---

Procedures Used:


Coliform, Total / E. coli (Qualitative) SM 20, 21-23 9223B (-04) (Colilert)

E. coli (Enumeration) SM 21, 23 9222A,B,C

Heterotrophic Plate Count SM 20, 21-23 9215B (-04)

**At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.**

Sample Qualifier:



Laboratory Director or Designee