



PO BOX 705
 NEWTONVILLE, NY 12128
 (518) 785-9839

LABORATORY REPORT

Sample ID JH2205963
 Federal Water Supply Code NY5730106 Supply Code 1952
 Water Supply Town of Salem Water Department DOH Glens Falls
 Address PO Box 57, 53 Stanton Salem NY 12865
 Sample Location Treatment Plant
 Date Collected 7/26/2022 Time Collected 9:15 AM
 Sample Collector Eric Rogers
 Date Printed 8/29/2022

Lab ID 10670 Date Analyzed 8/25/22

EPA 533 Perfluorinated and Polyfluorinated Alkyl Compounds

PARAMETER	CONCENTRATION ng/L	RL	MDL	PARAMETER	CONCENTRATION ng/L	RL	MDL	MCL
11CI-PF3OUdS	ND	1.8	0.45	PFBA	ND	4.5	1.8	
ADONA	ND	1.8	0.45	PFDA	ND	1.8	0.45	
4:2 FTS	ND	1.8	0.45	PFDoA	ND	1.8	0.45	
6:2 FTS	ND	12	5.4	PFHpS	ND	1.8	0.45	
8:2 FTS	ND	1.8	0.45	PFHpA	ND	1.8	0.45	
9CI-PF3ONS	ND	1.8	0.45	PFHxS	ND	1.8	0.45	
HFPO-DA	ND	1.8	0.89	PFHxA	ND	1.8	0.45	
NFDHA	ND	1.8	0.45	PFNA	ND	1.8	0.45	
PFEESA	ND	1.8	0.45	PFOS	ND	1.8	0.45	10 ng/L
PFMPA	ND	1.8	0.45	PFOA	ND	1.8	0.45	10 ng/L
PFMBA	ND	1.8	0.45	PFPeS	ND	1.8	0.45	
PFBS	ND	1.8	0.45	PFPeA	ND	1.8	0.45	
				PFUnA	ND	1.8	0.45	

PARAMETER	CONCENTRATION ug/L	MCL	RL	METHOD	Date Analyzed	Lab #
1,4-Dioxane	<0.100	1 ug/L	0.100	EPA 522	8/8/22	11549
Surrogate Recovery %						
1,4-Dioxane-d8	95.5					

Legend: RL = Report Limit
 MCL = Maximum Contamination Level
 ND - Not Detected
 MDL - Method Detection Limit
 J - Result is less than the RL but greater than or equal to the MDL and concentration is an approximate value.