



JH CONSULTING GROUP,  
INC  
PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

**SAMPLE INFORMATION**

<b>Sample ID</b>	JH2205978	<b>Supply Code</b>	1952				
<b>Federal Water Supply Code</b>	NY5730106	<b>DOH</b>	Glens Falls				
<b>Public Water Supply</b>	Town of Salem Water Department						
<b>Address</b>	PO Box 57, 53 Stanton Hill Road	<b>City</b>	Salem	<b>State</b>	NY	<b>Zip</b>	12865
<b>Sample Location</b>	MRT0001 Salem Rescue Squad Bldg, 152 E Broadway, kitchen cold water tap						
<b>Date Collected</b>	7/26/2022	<b>Time Collected</b>	9:45 AM	<b>Free Chlorine</b>	0.51 mg/L		
<b>Sample Collector</b>	Eric Rogers						
<b>Date Printed</b>	8/8/2022						

<b>EPA METHOD 524.2 Trihalomethanes (THM's)</b>	<b>Date Analyzed</b>	8/2/22	<b>NYS Lab</b>	12150
---	----------------------	--------	----------------	-------

<b>ANALYTE</b>	<b>CONCENTRATION UG/L</b>	<b>MCL*</b>	<b><u>METHOD</u></b>
Chloroform	24.3		EPA 524.2
Bromodichloromethane	3.61		EPA 524.2
Chlorodibromomethane	0.590		EPA 524.2
Bromoform	<0.500		EPA 524.2
Total Trihalomethane	28.5	80 ug/l	

Notes:

MCL\* is the Maximum Contaminant Level; A violation of the MCL occurs if the Locational Running Annual Average of the four most samples, by location, exceeds the MCL.

The above test procedures meet all the requirements of NELAC and related only to this sample