

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

April 13th 2022

- There are 316 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number.
- Regular upkeep and maintenance was performed.
- Had a hand full of dig safe mark outs
- Travis and I went to a water school.
- Mark Rode has been working on the update to the main water computer. There is still some work to be done. Well #2 has VFD drive issues that need to be fixed.
- The water tank is due for its 6 year cleaning and we also have one well up for its 3 year cleaning.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- We need to have the office door at the water barn replaced
- **I would like to thank everyone that cleaned out around fire hydrants!**
- We are going to try to paint 20-25 more hydrants this year.
- Started to clean main and hydrant valve's.
- Got my information to the Town web site person and hope its up on the page soon so if anyone wants to know some info on the water system its up there.

*****PLEASE NOTE*****

We will be flushing fire hydrants the week school is out in April.
This will be the week of the 18th - 22th of April.

Travis and I will be attending water school in Saratoga on the 13th of April.

Thank You,

Eric Rogers

Class C Water Plant Operator

