

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

February 9th

- There are 316 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number.
- Regular upkeep and maintenance was performed.
- I did a couple winter turn offs.
- Got system all ready for the up coming cold months.
- Please close off your basement windows and if you have a cold basement insulate your pipes so your not next freeze up! We had a hand full of freeze ups.
- All fire hydrants have been winterized and ready for winter.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- We need to have the office door at the water barn replaced
- **I would like to thank everyone that cleans out around fire hydrants!**
- One backflow device at water office passed the yearly inspection and one failed. The one that failed in is process of getting replace. I have the replacement part in the water office.
- Worked on getting some paperwork together. I would to have the Salem web page under the water line updated and add some new information and update some old.

*****If a hydrant has to be used PLEASE notify the water department as soon as possible so we can pump it out when done so it will not freeze*****

Thank You,

Eric Rogers

Class C Water Plant Operator