

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax(518)854-9712 --- Email: salemwaterdept@gmail.com

January 12th 2022

- There are 316 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number.
- Regular upkeep and maintenance was performed.
- I did a couple winter turn offs.
- Got system all ready for the up coming cold months.
- Please close off your basement windows and if you have a cold basement insulate your pipes so your not next freeze up!
- All fire hydrants have been winterized and ready for winter.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- We need to have the office door at the water barn replaced
- Will be doing 4th quarter Iron and Manganese in December also started my end of the year water withdraw DEC paperwork. 4th quarter Iron and Manganese results came back with ALL 3 wells and finished water being under the MCL limits.
- One backflow device at water office passed the yearly inspection and one failed. The one that failed in is process of getting replace.
- Worked on getting some paperwork together. I would to have the Salem web page under the water line updated and add some new information and update some old.

*****If a hydrant has to be used PLEASE notify the water department as soon as possible so we can pump it out when done so it will not freeze*****

Thank You,

Eric Rogers

Class C Water Plant Operator