

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

June 8th 2022

- There are 316 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number. I have changed a couple meter heads.
- Sand blasted some fire hydrants and started to repaint them.
- Regular upkeep and maintenance was performed.
- Had a hand full of dig safe mark outs
- we have a FREE water school coming up at the end of the month.
- Mark Rode has been working on the update to the main water computer. There is still some work to be done. Work has been getting done on updating the main operation computer to get it more user friendly.
- The water tank is due for its 6 year cleaning and we also have one well up for its 3 year cleaning. Hope to have it set up for late June. This is hopefully set up for the 15th of June.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- We need to have the office door at the water barn replaced
- We are going to try to paint 20-25 more hydrants this year.
- Got my information to the Town web site person and hope its up on the page soon so if anyone wants to know some info on the water system its up there. Hope the updated info is up soon.

Thank You,

Eric Rogers

Class C Water Plant Operator