

# **SALEM WATER DEPARTMENT**

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

## **September 2022 meeting**

- There are 317 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number. I have changed a couple meter heads.
- Regular upkeep and maintenance was performed.
- Had a hand full of dig safe mark outs
- Went to a free water school in - Whitehall
- Mark Rode has been working on the update to the main water computer. There is still some work to be done. Work has been getting done on updating the main operation computer to get it more user friendly. Had a drive issue that got fixed. Hope he has completed all that needs to be fixed.
- Found a broken line leaking water into a basement on South Main.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Health Law 225.
- Got back results from July round of testing - All is good.
- Got my information to the Town web site person and hope its up on the page soon so if anyone wants to know some info on the water system its up there. Hope the updated info is up soon. Hoping to hear that the updated info for water on the web page is done and I can get my thumb drive back.

\*\*\* We will start our fall hydrant flushing the week of Columbus day 10/10-14/2022. Please post this in the town paper \*\*\*

Thank You,

**Eric Rogers**

Class C Water Plant Operator