

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

April 2023

- There are 319 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number. I have changed a couple meter heads. We are looking into a more cost affective way to read meters and fix the “no or miss” reads.
 - I had no new water hook ups for the month
 - Regular upkeep and maintenance was performed.
 - New pumps are working good.
 - Had a hand full of dig safe mark outs.
 - NYS DOH Lead line inventory report is completed and we all set with it for now. We have no lead lines in our system as the system turned 20 this year.
 - Eye wash and Fire Extinguishers checks have been done.
 - We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
 - We did our 1st quarter Iron - Manganese sample. No results back yet.
-
- Flushing Fire Hydrants the week of the 10th - went good

Thank You,

Eric Rogers

Class C Water Plant Operator

