



# JH CONSULTING GROUP, INC

PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

## SAMPLE INFORMATION

Sample ID JH2301841 Customer Code 1952  
Federal Water Supply Code NY5730106  
Water Supply Town of Salem Water Department  
Address PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865  
Sample Location Raw Well 1  
Date Collected 3/9/2022 Free Chlorine Temperature  
Sample Collector Eric Rogers  
Date Printed 3/20/2023

## LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.157	<0.05 - 0.30	EPA 200.7	3/16/2023	11549
Manganese	0.118	<0.01 - 0.30	EPA 200.7	3/16/2023	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

page 1 of 1

The above test procedures meet all the requirements of NELAC and relate only to this sample

**SAMPLE INFORMATION**

Sample ID	JH2301842	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Raw Well 2		
Date Collected	3/9/2022	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	3/20/2023		

**LABORATORY REPORT**

ANALYTE	CONCENTRATION	MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron			<0.05 - 0.30	EPA 200.7		
Dissolved Manganese			<0.01 - 0.30	EPA 200.7		
Iron	<0.0500		<0.05 - 0.30	EPA 200.7	3/16/2023	11549
Manganese	0.262		<0.01 - 0.30	EPA 200.7	3/16/2023	115649
Thallium			0.002	EPA 200.8		
Sodium			***	EPA 200.7		
Aluminum				EPA 200.7		
Calcium				EPA 200.7		
Aluminum, Dissolved				EPA 200.7		
Total Dissolved Solids				SM2540C		
Ammonia				EPA 350.1		
Nickel						

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

page 2 of 1

The above test procedures meet all the requirements of NELAC and relate only to this sample



# JH CONSULTING GROUP, INC

PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

## SAMPLE INFORMATION

Sample ID JH2301843 Customer Code 1952  
Federal Water Supply Code NY5730106  
Water Supply Town of Salem Water Department  
Address PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865  
Sample Location Raw Well 3  
Date Collected 3/9/2022 Free Chlorine Temperature  
Sample Collector Eric Rogers  
Date Printed 3/20/2023

## LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	<0.0500	<0.05 - 0.30	EPA 200.7	3/16/2023	11549
Manganese	0.308	<0.01 - 0.30	EPA 200.7	3/16/2023	115649
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

page 3 of 1

The above test procedures meet all the requirements of NELAC and relate only to this sample





# JH CONSULTING GROUP, INC

PO BOX 705  
NEWTONVILLE, NY 12128  
(518) 785-9839

## SAMPLE INFORMATION

Sample ID JH2301844 Customer Code 1952  
Federal Water Supply Code NY5730106  
Water Supply Town of Salem Water Department  
Address PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865  
Sample Location Finished Water  
Date Collected 3/9/2022 Free Chlorine Temperature  
Sample Collector Eric Rogers  
Date Printed 3/20/2023

## LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	<0.0500	<0.05 - 0.30	EPA 200.7	3/16/2023	11549
Manganese	0.0991	<0.01 - 0.30	EPA 200.7	3/16/2023	115649
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

\*\*\* Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

page 4 of 1

The above test procedures meet all the requirements of NELAC and relate only to this sample