

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

May 17th Wednesday

- There are 319 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number. I have changed a couple meter heads. We are looking into a more cost affective way to read meters and fix the “no or miss” reads.
- I had no new water hook ups for the month
- Regular upkeep and maintenance was performed.
- New pumps are working good.
- Had a hand full of dig safe mark outs.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- Flushing Fire Hydrants went good.
- We are do for well #1 cleaning this year. Hope to be able to get that done soon.

Thank You,

Eric Rogers

Class C Water Plant Operator

- I will be attending water school to keep up on my water credits.
- 2nd quarter Ir + Mn test is in June

