

Queensbury Laboratory  
Accredited in accordance with NELAC

Queensbury Water Department  
823 Corinth Rd  
Queensbury, N.Y. 12804-9725  
(518) 793-8866  
New York State Certification # 10565  
EPA Lab Code # NY01262

Report of Bacteriological Examination

---

Date Collected: 6/6/2023

Date Tested: 6/6/2023

Collected By: Eric Rogers

Sample Point: Kitchen Faucet

Address of Sample: 11 McDougal St Salem, NY 12865-

Supplier: Salem Water Department

Fed Id: 5730106

Sample Number: 859

Time Collected: 8:30 AM

Time Tested: 1:20 PM

Sample Age (hours)

4.83

Total Coliform: Total Coliform Bacteria Absent per 100ml Sample

Heterotrophic Plate Count (#/1ml):

E. Coli:

Field tested Free Chlorine: 1.32

---

Procedures Used:

Coliform, Total / E. coli (Qualitative) SM 20, 21-23 9223B (-04) (Colilert)

Heterotrophic Plate Count SM 20, 21-23 9215B (-04)

**At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.**

Sample Qualifier:

*Susan Sheehan*

Laboratory Director or Designee