



PHASE II AND PHASE V MONITORING

SAMPLE INFORMATION

Sample ID	JH2305511	Customer Code	1952
Federal Water Supply Code	NY5730106	DOH	
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road	, Salem	, NY , 12865
Sample Location	Well 1 Raw		
Date Collected	7/11/2023	Time Collected	11:00 AM
Sample Collector	Eric Rogers	E-Mail	Salemwaterdept@gmail.com
Date Printed	7/17/2023		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	METHOD	MCL *	Date Analyzed	Lab ID Number
<i>INORGANICS Table 8C</i>					
		set up time			
Nitrate	0.079	10:30	Hach 10206	10 mg/l as N	7/16/2023 11799
Nitrite	NT		EPA 354.1	1 mg/l as N	

Notes:

MCL* is the Maximum Contaminant Level; it is the maximum concentration allowed in drinking water for a specific analyte as per NYS Sanitary Code. Hold time for nitrate per ELAP requirements is 48 hours for potable, non-chlorinated water samples and 14 days for potable, chlorinated water supplies. Samples for nitrate testing are also required to be received at 4 degrees Celsius or delivered to the laboratory on ice in the chilling process.

Legend: MG/L = Milligrams per Liter; <= Less Than; >= Greater Than;
mg/L = Parts per million; ug/L = Parts per billion; NT= Not Tested NC = Not Chlorinated

The above test procedures meet all the requirements of NELAC and relate only to these samples



PHASE II AND PHASE V MONITORING

SAMPLE INFORMATION

Sample ID	JH2305512	Customer Code	1952
Federal Water Supply Code	NY5730106	DOH	
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road, Salem, NY, 12865		
Sample Location	Well 2 Raw		
Date Collected	7/11/2023	Time Collected	11:00 AM
Sample Collector	Eric Rogers	E-Mail	Salemwaterdept@gmail.com
Date Printed	7/17/2023		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	METHOD	MCL *	Date Analyzed	Lab ID Number
<u>INORGANICS Table 8C</u>					
		set up time			
Nitrate	1.15	10:30	Hach 10206	10 mg/l as N	7/16/2023 11799
Nitrite	NT		EPA 354.1	1 mg/l as N	

Notes:

MCL* is the Maximum Contaminant Level; it is the maximum concentration allowed in drinking water for a specific analyte as per NYS Sanitary Code. Hold time for nitrate per ELAP requirements is 48 hours for potable, non-chlorinated water samples and 14 days for potable, chlorinated water supplies. Samples for nitrate testing are also required to be received at 4 degrees Celsius or delivered to the laboratory on ice in the chilling process.

Legend: MG/L = Milligrams per Liter; <= Less Than; >= Greater Than;
mg/L = Parts per million; ug/L = Parts per billion; NT= Not Tested NC = Not Chlorinated

The above test procedures meet all the requirements of NELAC and relate only to these samples



PHASE II AND PHASE V MONITORING

SAMPLE INFORMATION

Sample ID	JH2305513	Customer Code	1952
Federal Water Supply Code	NY5730106	DOH	
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road, Salem, NY, 12865		
Sample Location	Well 3 Raw		
Date Collected	7/11/2023	Time Collected	11:00 AM
Sample Collector	Eric Rogers	E-Mail	Salemwaterdept@gmail.com
Date Printed	7/17/2023		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	METHOD	MCL *	Date Analyzed	Lab ID Number
<u>INORGANICS Table 8C</u>					
		set up time			
Nitrate	1.22	10:30	Hach 10206	10 mg/l as N	7/16/2023 11799
Nitrite	NT		EPA 354.1	1 mg/l as N	

Notes:

MCL* is the Maximum Contaminant Level; it is the maximum concentration allowed in drinking water for a specific analyte as per NYS Sanitary Code. Hold time for nitrate per ELAP requirements is 48 hours for potable, non-chlorinated water samples and 14 days for potable, chlorinated water supplies. Samples for nitrate testing are also required to be received at 4 degrees Celsius or delivered to the laboratory on ice in the chilling process.

Legend: MG/L = Milligrams per Liter; <= Less Than; >= Greater Than;
mg/L = Parts per million; ug/L = Parts per billion; NT= Not Tested NC = Not Chlorinated

The above test procedures meet all the requirements of NELAC and relate only to these samples