



JH CONSULTING GROUP,
INC
PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

SAMPLE INFORMATION

Sample ID	JH2305514	Supply Code	1952				
Federal Water Supply Code	NY5730106	DOH	Glens Falls				
Public Water Supply	Town of Salem Water Department						
Address	PO Box 57, 53 Stanton Hill Road	City	Salem	State	NY	Zip	12865
Sample Location	MRT0001 Salem Rescue Squad Bldg, 152 E Broadway, kitchen cold water tap						
Date Collected	7/11/2023	Time Collected	8:00 AM	Free Chlorine	0.87 mg/L		
Sample Collector	Eric Rogers						
Date Printed	8/1/2023						

EPA METHOD 524.2 Trihalomethanes (THM's)	Date Analyzed	7/25/23	NYS Lab	12150
---	----------------------	---------	----------------	-------

ANALYTE	CONCENTRATION UG/L	MCL*	<u>METHOD</u>
Chloroform	5.43		EPA 524.2
Bromodichloromethane	1.67		EPA 524.2
Chlorodibromomethane	<0.500		EPA 524.2
Bromoform	<0.500		EPA 524.2
Total Trihalomethane	7.10	80 ug/l	

Notes:

MCL* is the Maximum Contaminant Level; A violation of the MCL occurs if the Locational Running Annual Average of the four most samples, by location, exceeds the MCL.

The above test procedures meet all the requirements of NELAC and related only to this sample