

Town Of Salem Water Department Maintenance Schedule (Wells & Tank)

Tank -

- The tank has a visual inspection once a year.
 - A walk around inspection twice a year when the fire hydrants are flushed.
 - The floor drain is flushed twice a year when the fire hydrants are flushed.
 - The over flow pipe is flushed twice a year when the fire hydrants are flushed.
 - There is a tank inspection from the inside done every 3 years and is cleaned inside every 6 years.
 - 2013 Inspection (Seaway Diving)
 - 2016 Cleaning with inspection (Seaway Diving)
 - 2019 Inspection (Seaway Diving)
 - 2022 Cleaning with inspection (Seaway Diving)
- Next Due
- 2025 - Inspection
 - 2028 - Cleaning with Inspection

Well -

● We try to do a well cleaning every year so the wells are on a 3 year rotation of getting cleaned. The cleaning involves pulling the well pump. Using air to clean the screen. Video inspection of the well. Disinfection of the well and parts removed. Install back together and follow DOH guidelines to get back in service.

- 2016 Well #1 - Cleaning (Mark Rogers)
- 2017 Well #3 - Cleaning (Mark Rogers)
- 2019 Well #2 - Cleaning (Mark Rogers)
- 2019 Well #1 - Cleaning (Mark Rogers)
- 2020 Well #3 - Cleaning (Mark Rogers)
- 2021 Well #1 - Cleaning (Mark Rogers)
- 2022 Well #2 - Cleaning (Mark Rogers)

Next Due

- 2023 Well #1 Cleaning
- 2024 Well #2 Cleaning
- 2025 Well #3 Cleaning

