

SALEM WATER DEPARTMENT

53 STANTON HILL ROAD, PoBox 575 SALEM, NY 12865

Phone and Fax 854-9712 --- Email salemwaterdept@gmail.com

September 2023

- There are 319 meters in service. I have looked over the meters in service some more and still looking over information to make sure it is the correct number. I have changed a couple meter heads. We are looking into a more cost affective way to read meters and fix the “no or miss” reads. To fix some no reads I’m looking into cell units?
- I had no new water hook ups for the month
- Regular upkeep and maintenance was performed.
- Had a hand full of dig safe mark outs.
- Eye wash and Fire Extinguishers checks have been done.
- We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.
- We did our 3rd Quarter Iron / Manganese sample.
- We did our well cleaning for Well#1. It went very good and it should be good for 3 more years. Well #3 got a new well level cable installed. Well #3 is up for clean in the 2024 year.
- Fall fire Hydrant flushing is going to happen the week of Columbus. This year we are having a flow test on hydrant #69 that will be done at the same time for the HHHN site to determine fire protection there. They are doing the test would us there to watch.

Thank You,

Eric Rogers

Class C Water Plant Operator