

Queensbury Laboratory
Accredited in accordance with NELAC

Queensbury Water Department
823 Corinth Rd
Queensbury, N.Y. 12804-9725
(518) 793-8866
New York State Certification # 10565
EPA Lab Code # NY01262

Report of Bacteriological Examination

Date Collected: 9/11/2023

Sample Number: 1362

Date Tested: 9/11/2023

Time Collected: 8:15 AM

Collected By: Eric Rogers

Time Tested: 1:50 PM

Sample Point: Kitchen Faucet

Address of Sample: 11 McDougal St Salem, NY 12865-

Supplier: Salem Water Department

Sample Age (hours)

Fed Id: 5730106

5.58

Total Coliform: Total Coliform Bacteria Absent per 100ml Sample

Heterotrophic Plate Count (#/1ml):

E. Coli:

Field tested Free Chlorine: 1.55

Procedures Used:

Coliform, Total / E. coli (Qualitative) SM 20, 21-23 9223B (-04) (Colilert)

Heterotrophic Plate Count SM 20, 21-23 9215B (-04)

At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.

Sample Qualifier:

Susan Sheehan

Laboratory Director or Designee