



SAMPLE INFORMATION

Sample ID	JH2501620	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Well 1 Raw		
Date Collected	3/4/2025	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	3/21/2025		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.145	<0.05 - 0.30	EPA 200.7	3/17/2025	11549
Manganese	0.114	<0.01 - 0.30	EPA 200.7	3/17/2025	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:



SAMPLE INFORMATION

Sample ID	JH2501621	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Well 2 Raw		
Date Collected	3/4/2025	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	3/21/2025		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	<0.0500	<0.05 - 0.30	EPA 200.7	3/17/2025	11549
Manganese	0.270	<0.01 - 0.30	EPA 200.7	3/17/2025	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



SAMPLE INFORMATION

Sample ID	JH2501622	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Well 3 Raw		
Date Collected	3/4/2025	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	3/21/2025		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	<0.0500	<0.05 - 0.30	EPA 200.7	3/17/2025	11549
Manganese	0.380	<0.01 - 0.30	EPA 200.7	3/17/2025	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample



SAMPLE INFORMATION

Sample ID	JH2501623	Customer Code	1952
Federal Water Supply Code	NY5730106		
Water Supply	Town of Salem Water Department		
Address	PO Box 57, 53 Stanton Hill Road , Salem , NY , 12865		
Sample Location	Finished Water		
Date Collected	3/4/2025	Free Chlorine	Temperature
Sample Collector	Eric Rogers		
Date Printed	3/21/2025		

LABORATORY REPORT

ANALYTE	CONCENTRATION MG/L	MCL	METHOD	Date analyzed	NYS Lab
Dissolved Iron		<0.05 - 0.30	EPA 200.7		
Dissolved Manganese		<0.01 - 0.30	EPA 200.7		
Iron	0.0716	<0.05 - 0.30	EPA 200.7	3/17/2025	11549
Manganese	0.0930	<0.01 - 0.30	EPA 200.7	3/17/2025	11549
Thallium		0.002	EPA 200.8		
Sodium		***	EPA 200.7		
Aluminum			EPA 200.7		
Calcium			EPA 200.7		
Aluminum, Dissolved			EPA 200.7		
Total Dissolved Solids			SM2540C		
Ammonia			EPA 350.1		
Nickel					

*** Water containing more than 20 mg/l sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Legend: NT= Not Tested

Notes:

The above test procedures meet all the requirements of NELAC and relate only to this sample