

**Queensbury Laboratory**  
**Accredited in accordance with NELAC**

Queensbury Water Department  
823 Corinth Rd  
Queensbury, N.Y. 12804-9725  
(518) 793-8866  
New York State Certification # 10565  
EPA Lab Code # NY01262

**Report of Bacteriological Examination**

Sample Number: 3908  
Date Collected: 1/12/2026  
Time Collected: 8:50 AM  
Collected By: Travis Keys  
Sample Point: Kitchen Faucet  
Supplier: Salem Water Department  
Address of Sample: 181 South Main St Salem, NY 12865-  
Fed ID: 5730106  
Sample Age (hours) 3.92

Total Coliform: Total Coliform Bacteria Absent per 100mL Sample  
Heterotrophic Plate Count (CFU/mL):  
*E. coli*: Negative  
Field Tested Free Chlorine (mg/L): 1.15

Procedures Used:  
Coliform, Total / *E. coli* (Qualitative) SM 20, 21-23 9223B (-04) (Coliert)  
Heterotrophic Plate Count SM 20, 21-23 9215B (-04)

At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.  
Sample Qualifier:

Laboratory Director or Designee

