

Public Water System Name	Reporting Month/Year	Date Report Submitted	Source of Water Supply:
Village of Salem Water Department	January 2026		<input type="checkbox"/> Surface <input checked="" type="checkbox"/> Ground <input type="checkbox"/> GWDI
Public Water System ID	County	Town, Village, or City	<input type="checkbox"/> Purchase with subsequent chlorination <input type="checkbox"/> Purchase w/out subsequent chlorination
5730106	Washington	Village of Salem	

DATE	Treated water volume (1,000 gallons/day)	Chlorination			Free chlorine residual at entry point (mg/l)	orthophosphate residual	Other Treatments / Readings
		Gasous	Liquid	Chlorination			
		Cylinder weight used per day (lbs.)	Chlorine used per day (lbs.)	Hypochlorite added to crock (gallons or quarts)			
1	44720				1.24	0.92	
2	44176				1.18	0.81	
3	55920				1.24	1.08	
4	41320				1.27	0.89	
5	57424				1.26	0.87	
6	43632				1.2	0.81	
7	69216				1.56	0.84	
8	42752				1.2	0.83	
9	58272				1.26	0.89	
10	41368				1.23	0.85	
11	67096				1.21	1.02	
12	46952				1.2	1.05	
13	63648				1.19	0.88	
14	41592				1.22	0.96	
15	59816				1.2	0.86	
16	42544				1.33	0.99	
17	55384				1.08	1.06	
18	41128				1.36	0.95	
19	54912				1.08	1.11	
20	41976				1.39	1	
21	54992				1.28	0.88	
22	41576				1.41	0.89	
23	58536				1.42	0.97	
24	40464				1.14	1.19	
25	57448				1.41	0.88	
26	42656				1.41	1.04	
27	60552				1.43	0.92	
28	99336				1.46	0.72	
29	56680				1.39	0.94	
30	42576				1.36	0.92	
31	54606				1.36	0.87	
Total	1623270					28.89	
AVG.	52363.548				1.28935	0.9319	

Does a M&R violation exist? No
 Does an MCL violation exist? No
 Does the system have a disinfection waiver? No

Reported by: TAVIS KEYS
 Signature: 
 Title: Water Plant Operator
 Certification Number: NY0041140
 Date: 2/3/26
 Operator Grade Level: C