

Queensbury Laboratory
Accredited in accordance with NELAC

Queensbury Water Department
823 Corinth Rd
Queensbury, N.Y. 12804-9725
(518) 793-8866
New York State Certification # 10565
EPA Lab Code # NY01262

Report of Bacteriological Examination

Date Collected: 3/3/2026

Date Tested: 3/3/2026

Collected By: Travis Keys

Sample Point: Kitchen Faucet

Address of Sample: 219 S Main St Salem, NY 12865-

Supplier: Salem Water Department

Fed Id: 5730106

Sample Number: 4032

Time Collected: 9:30 AM

Time Tested: 1:25 PM

Sample Age (hours)

3.92

Total Coliform: Total Coliform Bacteria Absent per 100mL Sample

Heterotrophic Plate Count (CFU/mL):

E. coli: Negative

Field Tested Free Chlorine (mg/L): 1.68

Procedures Used:

Coliform, Total / *E. coli* (Qualitative) SM 20, 21-23 9223B (-04) (Colilert)

Heterotrophic Plate Count SM 20, 21-23 9215B (-04)

At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.

Sample Qualifier:



Laboratory Director or Designee