


Water Systems Operation Report
Microbiological Sample Results

Public Water System Name		Reporting Month/Year		Date Report Submitted		Source of Water Supply:	
Village of Salem Water Department		March 2026				<input type="checkbox"/> Surface <input checked="" type="checkbox"/> Ground <input type="checkbox"/> GWUDI <input type="checkbox"/> Purchase with subsequent chlorination <input type="checkbox"/> Purchase w/out subsequent chlorination	
Public Water System ID		County		Town, Village, or City			
5730106		Washington		Village of Salem			
DATE	Treated water volume (1,000 gallons/day)	Chlorination				Other Treatments / Readings	
		Gaseous Cylinder weight (lbs.)	Chlorine used per day (lbs.)	Liquid Hypochlorite added to crock (gallons or quarts)	Free chlorine residual at entry point (mg/l)	orthophosphate residual	
1	47697				1.73	0.81	
2	81992				1.59	0.78	
3	44003				1.65	0.88	
4	79332				1.58	0.78	
5	46664				1.36	0.93	
6	73688				1.64	0.9	
7	46328				1.56	0.89	
8	76232				1.66	0.8	
9	48048				1.51	0.92	
10	74832				1.52	0.97	
11	58332				1.06	0.95	
12	68984				0.88	0.86	
13	47848				1.29	0.82	
14	66792				1.3	1.02	
15	61240				1.18	0.81	
16	94040				1.36	0.9	
17	50992				1.37	0.94	
18	91640				1.42	0.85	
19	51472				1.52	0.9	
20	89696				1.48	0.82	
21	52024				1.48	0.89	
22	84936				1.53	0.79	
23	52112				1.34	0.93	
24	96160				1.49	0.79	
25	50192				1.46	0.83	
26	90464				1.46	0.91	
27	52624				1.56	0.86	
28	93040				0.77	1.13	
29	51120				0.89	0.85	
30	101576				1.02	0.76	
31	50608				0.95	0.91	
Total	2074708					27.18	
AVG.	66926.065				1.37452	0.876774194	

Does a M&AR violation exist? No Does an MCL violation exist? No Population Served 915
 Did an emergency occur in any part of the water system? No Does the system have a disinfection waiver? No

Reported by: Travis Keys Title: Water Plant Operator Certification Number: NY0041440
 Signature:  Date: 4/7/2026 Operator Grade Level: C