

Queensbury Laboratory  
Accredited in accordance with NELAC

Queensbury Water Department  
823 Corinth Rd  
Queensbury, N.Y. 12804-9725  
(518) 793-8866  
New York State Certification # 10565  
EPA Lab Code # NY01262

Report of Bacteriological Examination

---

Date Collected: 10/8/2025

Date Tested: 10/8/2025

Collected By: Travis Keys

Sample Point: Well #2

Sample Number: 3670

Time Collected: 11:30 AM

Time Tested: 12:50 PM

Address of Sample: 53 Stanton Rd Salem, NY 12865-

Supplier: Salem Water Department

Fed Id: 5730106

Sample Age (hours)

1.33

Total Coliform: Total Coliform Bacteria Absent per 100mL Sample  
Heterotrophic Plate Count (CFU/mL):

*E. coli*: Negative

Field Tested Free Chlorine (mg/L):

---


Procedures Used:

Coliform, Total / *E. coli* (Qualitative) SM 20, 21-23 9223B (-04) (Colilert)

Heterotrophic Plate Count SM 20, 21-23 9215B (-04)

**At the time the sample was submitted, the sample MET the bacteriological requirements for a public water supply as set forth in Subpart 5-1.51 of the State Sanitary Code under Public Health Law, Section 225.**

Sample Qualifier:



Laboratory Director or Designee