


NEW YORK STATE DEPARTMENT OF HEALTH
Bureau of Water Supply Protection

Water Systems Operation Report
Microbiological Sample Results

Public Water System Name		Reporting Month/Year		Date Report Submitted		Source of Water Supply:	
Village of Salem Water Department		August 2026				☐ Surface ☒ Ground ☐ GWUDI ☐ Purchase with subsequent chlorination ☐ Purchase w/out subsequent chlorination	
Public Water System ID		County		Town, Village, or City			
5730106		Washington		Village of Salem			

DATE	Treated water volume (1,000 gallons/day)	Chlorination				Other Treatments / Readings		
		Gaseous		Liquid	Free chlorine residual at entry point (mg/l)	orthophosphate residual		
		Cylinder weight (lbs.)	Chlorine used per day (lbs.)					
1	54056				1.38	0.75		
2	50152				1.38	0.82		
3	56408				1.3	0.92		
4	63968				1.26	0.84		
5	48624				1.34	1.1		
6	59192				1.32	0.83		
7	56072				1.28	0.89		
8	67020				1.45	0.93		
9	54888				1.34	0.87		
10	62236				1.29	0.95		
11	57672				1.34	0.88		
12	65776				1.29	0.78		
13	55696				1.29	0.79		
14	43064				1.23	0.83		
15	80652				1.4	0.82		
16	48232				1.79	0.92		
17	65488				1.32	0.88		
18	38416				1.3	0.8		
19	54040				1.32	0.87		
20	55568				1.29	0.84		
21	56128				1.19	0.89		
22	56976				1.39	0.82		
23	53920				1.29	0.9		
24	51424				1.31	0.79		
25	55648				1.35	0.84		
26	58184				1.18	0.98		
27	60016				1.32	0.99		
28	66096				1.27	1.01		
29	54112				1.3	0.95		
30	42112				1.51	0.98		
31	52984				1.25	1.05		
Total	1744820					27.51		
AVG.	56284.516				1.33129	0.8874		

Does a M&AR violation exist? No Does an MCL violation exist? No Population Served 915
 Did an emergency occur in any part of the water system? No Does the system have a disinfection waiver? No
 Reported by: Travis Keys Title: Water Plant Operator Certification Number: NY0041140
 Signature:  Date: 9/3/26 Operator Grade Level C